

Ross County Health District Food Service Inspection Summary



Name of Establishment: Christopher Conference Center
Address: 20 North Plaza Blvd., Chillicothe
Date of Inspection: June 7, 2010
Reason for Inspection: Standard Inspection
Sanitarian Performing Inspection: Kelly Dennis, R.S.

Violation(s) / Comment(s) (Chapter 3717-1 OAC violations checked)

Standard licensing inspection conducted. Cold reach cooler has been repaired and holding food below 41°F. Dishmachine has been repaired and sanitizer at 100ppm chlorine. Dirty dish racks have been discarded as well as damaged equipment.

***05.3 Water, Plumbing, and Waste: Sewage, Other Liquid Waste, and Rainwater**

(C) Backflow prevention.

Food prep sink drain line does not have airgap. Provide airgap to prevent backflow of sewage into prep sink. Correct before using sink.

04.4 Equipment, Utensils, and Linens: Maintenance and Operation

(A) Equipment - good repair and proper adjustment.

Door / door gasket on ice machine bin in poor repair. Repair or replace. Operation noted a new ice bin will be ordered if door can not be repaired. Correct by 30 day inspection. Equipment shall be in good repair.

License Issued

****DISCLAIMER:** This summary reflects only the conditions found on the date of the inspection and does not necessarily reflect conditions at all times. Inspection reports can be viewed in their entirety at the Ross County Health District's Environmental Health Office, 475 Western Ave., Suite 3A, Chillicothe, Ohio.