

Ross County Health District

Food Service Inspection Summary



Name of Establishment: Paradise Pizza
Address: 11610 U.S. 50, Bourneville
Date of Inspection: February 18, 2010
Reason for Inspection: Standard Inspection
Sanitarian Performing Inspection: Andrew L. Gedeon, R.S.

Violation(s) / Comment(s) (Chapter 3717-1 OAC violations checked)

1) ***CRITICAL VIOLATION*** Observed food debris build-up on the inside of the microwave oven. Food contact surfaces must remain clean to sight and touch to prevent possible contamination of food. The microwave was cleaned at the time of inspection.

3717-1-04.5 Equipment, Utensils, and Linens: Cleaning of Equipment and Utensils

- (B) **Equipment food-contact surfaces and utensils - cleaning frequency.**
 - (1) **Equipment food-contact surfaces and utensils shall be cleaned:**
 - (e) **At any time during the operation when contamination may have occurred.**

2) ***CRITICAL VIOLATION*** Observed an inadequate air gap on the vegetable prep sink.

3717-1-05.1 Water, Plumbing, and Waste: Plumbing System

- (D) **Backflow prevention - air gap.**

An air gap between the water supply inlet and the flood level rim of the plumbing fixture, equipment, or nonfood equipment shall be at least twice the diameter of the water supply inlet and may not be less than one inch (twenty-five millimeters).

SUMMARY

Cold holding temperatures appear to be below 41 degrees F. No food prep or hot holding at the time of inspection. Hot water appears to be adequate in all sinks. Thermometer and test strips available. Sanitizer appeared to be at the proper concentration.

****DISCLAIMER:** This summary reflects only the conditions found on the date of the inspection and does not necessarily reflect conditions at all times. Inspection reports can be viewed in their entirety at the Ross County Health District's Environmental Health Office, 475 Western Ave., Suite 3A, Chillicothe, Ohio.